

CITY OF SUNRISE BEACH VILLAGE

Life is Better on the Beach!



124 Sunrise Drive
Sunrise Beach, Tx 78643
www.sunrisebeachtx.gov
water@sunrisebeachtx.gov

Sean Schreiber
Water Department Supervisor



April 2026 water report

Repairs : 2
Meters changed : 15
Installs : 0

6th-8th - Meter Reading

8th- 2014 f250 had EGR pump go out again/replaced under warranty. Oil pan was warped and replaced.

9th - Sent out Lead Service Line Inventory Letters to customers who's lines are unknown per TCEQ or face a fine.
We are now compliant with TCEQ on this matter.

13th- Rereads

15th- CCR was completed for year 2025 and sent to printers.
2014 F250 back from repairs.

20th- Smith pump installed new high service pump and took old one back for rebuild.

21st- Bac-T samples collected and sent to lab.

24th- Hired our 3rd man for the water department. (Jordan King)

27th- Flushing

27th-29th- Sean in class for CEU's

29th-1st- Ryan in class for CEU's

March Water Loss : 3/5 - 4/7

Pumped : 3,930,281gal.

Sold : 3,092,100gal.

Tanks & Pipes : 250,000gal.

flushed : 4,150gal.

Loss : 584,031gal. 15%

Report completed by: *Sean Schreiber*

Water Department Supervisor