

CITY OF SUNRISE BEACH VILLAGE

Life is Better on the Beach!



124 Sunrise Drive
Sunrise Beach, Tx 78643
www.sunrisebeachtx.gov
water@sunrisebeachtx.gov

Sean Schreiber
Water Department Supervisor

July 2026 water report

Repairs : 3
Meters changed : 21
Installs : 0
Work Orders/other: 20

2nd- 02 F250 back from shop
6th-7th : Meter Reading
8th- Water Committee meeting
9th- Door tags and rereads
10th- Precision Calibrate calibrated plant and well meters.
16th-Completed DLQOR & mailed it to TCEQ.
21st- Bac-T samples and started flushing
22nd- completed flushing
23rd- Changed CI2 bottles and CI17 bottles. Investigated unknown valves in the system. Water committee meeting.
28th- Water Committee meeting.

June Water Loss : 6/5 to 7/7

Pumped : 4,923,179gal.

Sold/Metered : 4,089,000gal.

Tanks & Pipes : 250,000gal.

Flushed/leaks : 5,000gal.

Loss : 579,179gal. 11.5%

Report completed by: *Sean Schreiber*

Water Department Supervisor