CITY OF
SUNRISE BEACH VILLAGE

Life is Better on the Beach!

5K

124 Sunrise Drive
Sunrise Beach, Tx 78643
www.sunrisebeachtx.gov
water@sunrisebeachtx.gov

Sean Schreiber
Water Department Supervisor

September 2026 water report

Repairs : 8
Meters changed : 6
Installs : 0
Work Orders/other: 11

2th-3th : Meter Reading
9th-10th: 2" line extension on Circle.
11th- Door tags
15th- Stop the bleed class & Bac-T samples completed
17th- Hach Technician here servicing the Chlorine analyzers.
21st- Circle line ext. sample was good, line was put into service.
28th-29th: Smith Pumps Technician installed new HSP#3.
29th- Flushing
30th- DLQOR for TCEQ was completed. 2002 F250 went to the shop for a coolant leak missed from the previous visit.

August water loss: 8/7 – 9/3

Pumped: 4,628,104gal.

Sold: 4,153,300gal.

Pipes&Tanks: 250,000gal.

Leaks&Flushed: 18,425gal.

Loss: 206,379gal. 4.5%

Report completed by: *Sean Schreiber*

Water Department Supervisor